



- ➔ For generator applications: L1 120v must be fed from utility side not through generator power.
- ➔ 25a relays connected to remote start contacts in ATS. Can be NC or NO.
- ➔ Request appropriate switches (up to 3); all switches are interchangeable
- ➔ Ripple must be in a waterproof environment.
- ➔ Normal off-peak "not controlled" position is "a", or UP position.

TO SCHEDULE AN APPOINTMENT WHEN COMPLETE
CALL 356-4400 OR 800 248-3292 AND ASK FOR
ENERGY MANAGEMENT



Cass County
Electric Cooperative, Inc.
KINDRED, NORTH DAKOTA

ROA RIPPLE CONTROL

DRAWN BY: JLB

CAD NAME: ROA

REV BY: NWL

DATE: 9/5/99

SHEET | OF |

REV DATE: 05/22/09